



**NOTES:**

- DO NOT USE EQUIPMENT TO SUPPORT OTHER PARTS OF THE EXHAUST SYSTEM WITHOUT PROPER REINFORCEMENT

**MATERIAL CONSTRUCTION:**

- 304 STAINLESS STEEL

**PAINT:**

- NONE (MIRATECH COATING SYSTEM 4)

PROJECT NAME	<b>PROPRIETARY AND CONFIDENTIAL</b> THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH IS PROHIBITED.	ALL DIMENSIONS IN INCHES (MILLIMETERS) UNLESS OTHERWISE SPECIFIED. CRITICAL DIMENSIONS ARE <b>CIRCLED</b>			
PROPOSAL NUMBER		TOLERANCES UNLESS OTHERWISE SPECIFIED < 12 [305] $\pm$ 1/8 [3] 12 [305] $\geq$ 36 [915] $\pm$ 3/16 [5] 36 [915] $\geq$ 360 [9150] $\pm$ 5/16 [9] > 360 [9150] $\pm$ 7/16 [12]		<b>M5GE0-30PF-3-00000095</b> SILENCER HOSPITAL GRADE M52	
SALES ORDER NO.		DRAWN: HHK DATE: 2025/06/03 REVIEWED: CSF DATE: 2025/06/03		SALES DRAWING M5GE0-30PF-3-00000095 SD	
CUSTOMER P.O. [P.N.]		PROJECTION 		SIZE: A	SCALE: 1:66 WEIGHT: 5612lb/2550kg